



City of Richmond

June 1, 2011
File: 02-0775-50-4228/Vol 01

**Business and Financial Services
Department
Finance Division**
Telephone: 604-276-4218
Fax: 604-276-4162

Attention: To All Bidders

Dear Sir/Madame:

Re: Request for Quotation 4228Q Supply & Install Back-Up Power for the Richmond Ice Centre – Addendum One

This Addendum includes items of clarification, forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your quotation:

See attached from Nemetz (S/A) & Associates Ltd.

Signature, Name and Title

Yours truly,

A handwritten signature in black ink, appearing to read "Sumita Dosanjh".

Sumita Dosanjh
Buyer II - Contracting Specialist



Nemetz (S/A) & Associates Ltd.
Electrical Consulting Engineers

2009 West 4th Avenue
Vancouver, BC V6J 1N3

Phone: (604) 736-6562
Fax: (604) 736-9805

Electrical Addendum #1
Standby Generator – Richmond Ice Centre
14140 – Triangle Road, Richmond BC

City of Richmond - Richmond Ice Centre
14140 Triangle Road
Richmond BC

Nemetz (S/A) & Associates Ltd.
Electrical Consulting Engineers
2009 West 4th Avenue
Vancouver, BC
V6J 1N3

Attention: Gregg Wheeler / Sumita Dosanjh

Email: gwheeler@richmond.ca, sdosanjh@richmond.ca

File No.: 11776

Date: May 30, 2011

Page 1

Message:

This addendum contains 1 page.

Clarify: 1. Generator main breaker shall be rated for 400Amps.

Add: 1. Provision for additional 200Amp breaker shall be included on generator (for future use only). This applies to specified 400kW and separate price 450kW units.

2. One (1) new battery pack lighting in electrical room and two (2) new battery pack lights in mechanical room. Connect battery packs to room lighting circuits. Battery packs shall be Beghelli–Nova–25W–PAR26-12volt model or equal.

~ End of Electrical Addendum #1~

As Per: Darren Neuman
NEMETZ (S/A) & ASSOCIATES LTD.

DN