



March 14, 2012
File: 02-0775-50-4608/Vol 01

Attention: To All Proponents

**Re: Request for Proposal 4608P Bucket Spectator Seating for the Richmond Olympic Oval
– Addendum No. 3**

This Addendum includes items of clarification; forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your proposal

I. Questions and Answers

- Q.1 What are the gap/doorway width restrictions when moving the typical and atypical seating riser units from storage position in the hockey arena to concert mode in the performance arena? Or are there no walls separating the two sections of the facility?
- A.1 No walls separating sections. The entire floor is open space.
- Q.2 Do you require closure panels (aluminum fascia panels) along the front of the tiered seating riser sections? Or will you allow gaps between tiers?
- A.2 Closure panels not required.
- Q.3 Will floor mounted seating be acceptable? Or do you require nose-mounted seats?
- A.3 Floor mounted seats will not be accepted by the City.
- Q.4 Will guardrails along the side of typical and atypical seating riser sections remain installed when the seating riser sections are positioned next to one another? Or will the guardrails need to be removed (creating a double-wide aisle way for option A) If the guardrails are to be removed, will they need to be replaced with center-aisle handrails?
- A.4 Guardrails along the side will remain installed. If operator needs, should be detachable.
- Q.5 Do the walkways that run along the ice rink boards for storage position (storage position rows 2, 3 and 4) need to be mobile? Or can they be supported using a static-height version of our SC9600 support structure (see attached). In other words, do the storage mode walkways need to have casters and do they need to break apart into sections?
- A.5 The walkways will not be mobile.

- Q.6 Will the storage mode walkways remain in position when the risers are in concert mode? If so, will you require additional skirting and guardrails to attach to the side of the walkway when the seating risers are in concert mode? At the end of some of the walkways, the ice rink boards appear in the drawings to be curving away from the edge of the walkway. Will these gaps require guardrails? Or will you require custom platforms to curve and remain flush with the boards?
- A.7 The walkways will remain in position around the ice rinks when bleachers are relocated to the other end of the Oval during a concert. No extra skirting.
Where ice rink curves away at the end of the walkways, a custom walkway that curves with the rink is required.

II. Extension to Closing Date

Please be advised that the Closing Date has been revised as follows:

WAS: Wednesday, March 21st, 2012 at 12:00 noon
IS NOW: Friday, March 23rd, 2012 at 12:00 noon

Proponents must sign and include this Addendum with their submission.

Signature, Name and Title

Yours truly,



FOR:
Sumita Dosanjh, SCMP
Buyer II – Contracting Specialist