

CITY OF RICHMOND INVITATION TO TENDER

Contract T.3037

Contract: Lancing Subdivision Watermain Replacement

The City of Richmond invites tenders for construction work at the above-mentioned locations. Work under the Contract generally comprises:

Supply & Installation of 2,255 lineal metres of 200mm, 150mm & 100mm dia. watermain. Supply and installation of 14 fire hydrants and 160 service connections.

The *Contract Documents* are available on or after December 18, 2007 during normal business hours at Front of House of the Richmond City Hall at:

6911 No. 3 Road, Richmond, BC, V6Y 2C1

Note: City Hall will be closed from Dec 24 to Jan 1

on payment of a **non-refundable** amount of \$50.00 including GST payable to:

City of Richmond

The *Contract Documents* are available for viewing at:

Front of House, Richmond City Hall, 6911 No. 3 Road, Richmond and Vancouver Regional Construction Association, 3636 East 4th Avenue, Vancouver.

Tenders are scheduled to close at:

Tender Closing Time: 3:00 PM local time

Tender Closing Date: Tuesday, January 15, 2008 and will be opened publicly immediately thereafter at Richmond City Hall.

Tender Submission Address: Manager – Purchasing & Risk
Front of House, Richmond City Hall
6911 No. 3 Road, Richmond, BC, V6Y 2C1

A valid tender consists of a submission delivered on time complete with the required Bid Bond, Undertaking of Surety and Undertaking of Liability Insurance.

The lowest or any tender will not necessarily be accepted.

Manager – Purchasing & Risk

CITY OF RICHMOND

**Contract No. T.3148
Supply and Delivery of STREET LIGHTING AND TRAFFIC SIGNAL
POLES FOR NO. 3 ROAD RESTORATION**

Addendum No. 01

Date: January 02, 2008

Tenderers are advised that Addendum No. 01 to Contract T.3148 is hereby issued by the City of Richmond.

Tenderers shall:

1. Sign this copy of the Addendum and return within 24 hours to the City of Richmond by facsimile (604-276-4277) or e-mail DTyler@richmond.ca.
2. Take into account the content of this Addendum in the preparation of the tender.

ACKNOWLEDGMENT

Addendum No. 01, two (2) pages in total received,
And content noted.

(Signature)

Position: _____

Firm Name: _____

Contract No. T.3148

**Supply and Delivery of STREET LIGHTING AND TRAFFIC SIGNAL
POLES FOR NO. 3 ROAD RESTORATION**

ADDENDUM No. 01

This addendum forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. The costs of all work contained herein shall be included in the Contract Price. The following revisions supercede the information contained in the original Contract Document to the extent referenced and shall become part thereof.

This addendum contains two (2) pages in total consisting of the following:

- 1 page that acknowledges receipt of this addendum;
- 1 page describing the text or drawing amendments relating to Addendum No. 01;

1. SPECIFICATIONS

9. Powder Coating, page 13 delete in its entirety the first sentence containing the following “All powder coating shall be by White Powder Coating, Surrey, BC or Valmont Industries.” and replace with the following “All powder coating shall be by an experienced powder coating company in accordance to the specifications contained herein.”

End Addendum No. 01



City of Richmond

6911 No. 3 Road, Richmond, BC V6Y 2C1

Telephone (604) 276-4000

www.city.richmond.bc.ca

January 8, 2008

File: 02-0775-50-3037/Vol 01

Business & Financial Services Department

Finance Division

Telephone: 604-276-4218

Fax: 604-276-4162

Attention: All Tenderers

Dear Sir/Madam:

Re: T.3037 - Lancing Subdivision Watermain Replacement – Addendum No. 2

Please disregard the previous addendum posted to this tender on the City of Richmond website dated January 2, 2008. That addendum is related to another, separate tender and was posted to this tender in error.

Yours truly,


Kerry Lynne Gillis
Buyer II - Contracting Specialist

KG:kg



City of Richmond

6911 No. 3 Road, Richmond, BC V6Y 2C1
Telephone (604) 276-4000
www.city.richmond.bc.ca

January 10, 2008
File: 10-6340-20-P.07405/Vol 01

Engineering
Telephone: 604-276-4289
Fax: 604-276-4197

TO THOSE WHO HAVE RECEIVED COPIES OF T.3037

Dear Sir/Madam:

**Re: Contract T.3037
Addendum No. 3
Lancing Subdivision Watermain Replacement**

This addendum forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. The costs of all work contained herein shall be included in the Contract Price. The following revisions supersede the information contained in the original Contract Document to the extent referenced and shall become part thereof.

Tenderers shall acknowledge receipt of this addendum by inserting its number and date where provided for on the Form of Tender.

1. Contract Drawings

Drawing Wc-884, sheet 1 of 3, is revised as follows:

Delete the note at the top of the page stating

**WATERMAIN CONSTRUCTION ALONG LANCING ROAD FROM STATION 0+80.80 TO 1+95.06
USING TRENCHLESS TECHNOLOGY**

and replace with

**WATERMAIN CONSTRUCTION ALONG LANCING ROAD FROM STATION 0+80.80 TO 1+95.06
MAY BE CONSTRUCTED USING TRENCHLESS TECHNOLOGY**

2. Clarification - Watermain trench restorations in driveways

Where the new watermain crosses an existing driveway that is near or at the road shoulder the asphalt trench restoration width will be from the excavated trench to the road edge.

3. Questions Received from Contractors & Subsequent Answers

- Q Can PVC bends be used for watermain construction?
A: Yes, PVC bends may be used as per MMCD 02666 2.2.4.4 and 2.2.4.5

2. Q: Is tracer wire required for main line and service connections?


A: Tracer wire is required for all service connections refer to City of Richmond "Supplementary Specifications and Detail Drawings"

- Specification 3.10.13 and detail drawing W2a-SD/W2b-SD

3. Q: What type of main line valve box cover is required?

A: Westview sales Tr-10A valve box is required for main line valves as per "Supplementary Specifications and Detail Drawings" W3a-SD.

Yours truly,



Mile Racic
Engineering & Public Works