



City of Richmond

Business and Financial Services Department
Finance Division
Telephone: 604-276-4218
Fax: 604-276-4162

December 21, 2011
File

Attention: To All Proponents

Dear Madame/Sir:

Re: T.4618 – Multi-Family Water Meter Installations - Addendum # 2

This Addendum includes items of clarification, forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your tender:

Remove:

Page 23, Part – C – Requirements, section 1.1 – Exterior underground installations; and page 24, 1.3, e; and page 27 “Schedule of Prices”; and Appendix A: Specifications and Requirement for the work :

1) 8311 Saunders Rd

Clarification:

Appendix A – Specifications and Requirements for Work:

1) 11240 Mellis Dr.

There is an one (1”) inch line that branches from the main fire line to the parkade. No re-plumbing required; leave as is.

2) 7580 Minoru Blvd.

Confirmation as per specs: Fire line can be upstream of water meter.

3) 7540 Minoru Blvd.

Confirmation as per specs: Cap hose bib connections upstream of water meter; relocate downstream of meter.

4) 7540 Minoru Blvd (Recreational Building)

Water meter to be located under kitchen sink.

Add:

1) 8751 General Currie Rd.

Supply and install double check valve for irrigation line to meet plumbing code. Add this line item to page 27 and include price in total tender price on page 26. Indicate price here:

\$_____ + Tax

2) 7540 Minoru Blvd.

Supply and install double check valve for irrigation line to meet plumbing code. Add this line item to page 27 and include price in total tender price on page 26. Indicate price here:

\$_____ + Tax

Please acknowledge receipt of this addendum by submitting a signed copy with your response.

Signature

Print Name & Title

Date

Yours truly

Daianna Panni
Buyer