



City of Richmond

6911 No. 3 Road,
Richmond, BC V6Y 2C1
www.richmond.ca

January 29, 2014

File: 10-6340-20-P.14201/Vol 01

Engineering and Public Works

Telephone: 604-276-4067

Fax: 604-276-4222

TO THOSE WHO HAVE RECEIVED COPIES OF T.5086

Attention: To All Tenderers

Dear Sir/Madame:

Re: Contract T.5086 – 2014 Asphaltic Concrete Paving - Addendum Five

This addendum forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. The costs of all work contained herein shall be included in the Contract Price. The following revisions supersede the information contained in the original Contract Document to the extent referenced and shall become part thereof.

I. Revision to the Average Milling Depth Range:

Question No.1 Milling depths available? And if not will you provide us with an average depth?

City's response Milling depths may vary between 0mm to 150mm. If the actual depth exceeds the noted range then the Contract Administrator will seek the reflective cost changes under MMCD prescribed CCO and CO process.

End of Addendum Five

Regards,

Wasim Memon
Contract Administrator

WM:wm

pc: Milton Chan
Manager, Engineering Design & Construction
Julia Turick
Buyer 2