



City of Richmond

6911 No. 3 Road,
Richmond, BC V6Y 2C1
www.richmond.ca

January 29, 2014

File: 10-6340-20-P.14201/Vol 01

Engineering and Public Works
Telephone: 604-276-4067
Fax: 604-276-4222

TO THOSE WHO HAVE RECEIVED COPIES OF T.5086

Attention: To All Tenderers

Dear Sir/Madame:

Re: Contract T.5086 – 2014 Asphaltic Concrete Paving - Addendum Six

This addendum forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. The costs of all work contained herein shall be included in the Contract Price. The following revisions supersede the information contained in the original Contract Document to the extent referenced and shall become part thereof.

I. Glass Grid Material Approved for Use in the City of Richmond:

Question No.1 In regards to the above tender, what are the material specifications acceptable for the Glass Grid employed or accepted for use on this project? There are a variety of products available, and MMCD only gives requirements and strength parameters and material specifications for Geotextiles, not geogrids. MMCD says to refer to the supplementary specifications for each particular contract, or to the Inspectors requirements. In the past we have used one type of adhesive product, just want verification of acceptable limits due to the nature of all the different products available today.

City's response **The City currently approves Nilex Geo Grid material specified under product numbers 8501 and 8511. Other manufactured products offered by Checkmate Geosynthetics of comparable properties may also be considered.**

End of Addendum Six

Regards,

Wasim Memon
Contract Administrator

WM:wm

pc: Milton Chan
Manager, Engineering Design & Construction
Julia Turick
Buyer 2